



INSTITUTE FOR TESTING AND CERTIFICATION
T. BATI 299, 764 21 ZLÍN, CZECH REPUBLIC


FINAL TEST REPORT

Reference No. 35 35 00081 / 2010 /B

Client : **Zakłady Tworzyw Sztucznych „Gamrat“
Spółka Akcyjna (INC.)
St. Mickiewicza 108
38-200 Jasło, Poland**


Product: **PVC floor covering Centra 43, overall thickness of
2.0 mm**

Manufacturer: **Zakłady Tworzyw Sztucznych „Gamrat“
Spółka Akcyjna (INC.)
St. Mickiewicza 108
38-200 Jasło, Poland**

Elaborated by : Dipl. Ing. Milan Kovář 

Issued on : 2010-04-22




RNDr. Radomír Čevelík
general director

1. Scope of tested properties, testing methods

The client requested to determinate following properties:

- Slip resistance (dynamic coefficient of friction on dry floor surfaces) according to ČSN EN 14041, ČSN EN 13893

2. Place and scope of sampling

Following samples were supplied by the client:

- PVC floor covering Centra 43, overall thickness of 2.0 mm, in quantities of 2 pcs (500 x 1000) mm

The samples were supplied and registered on 22nd March 2010 under the registration No. 353500081/2.

3. Test results

Floor covering	Dynamic coefficient of friction on dry floor surfaces	
	Determined values (lengthwise/crosswise)	Requirement for compliance of class DS, according to ČSN EN 14041
Centra 43	0.36 / 0.41	Min. 0.3

4. Conclusion

The test results are given in Art. 3. PVC covering fulfil „DS“ slip resistance class according to ČSN EN 14041.